


March 10, 1996

T-BRACE DETAIL

ST - T-BRACE




MITek Industries, Inc. Chesterfield, MO.

Nailing Pattern		
T-Brace size	Nail Size	Nail Spacing
1x4 or 6	10d	8" o.c.
2x4, 6, or 8	16d	8" o.c.

**Note: Nail along entire length of T-Brace
(On Two-Ply's Nail to Both Plies)**

Note: T-Bracing to be used when continuous lateral bracing is impractical. T-brace must cover 90% of web length.



Web Size	T-Brace Size for One-Ply Truss	
	Specified Continuous Rows of Lateral Bracing	
	1	2
2x3 or 2x4	1x4	2x4
2x6	1x6	2x6
2x8	2x8	2x8

Web Size	T-Brace Size for Two-Ply Truss	
	Specified Continuous Rows of Lateral Bracing	
	1	2
2x3 or 2x4	2x4	2x4
2x6	2x6	2x6
2x8	2x8	2x8

T-Brace must be same species grade (or better) as web member.